



Miami Shores Village

10050 N.E. SECOND AVE.
MIAMI SHORES, FLORIDA 33138-2382
Telephone: (305) 795-2207
Fax: (305) 756-8972

DAVID A. DACQUISTO, AICP
PLANNING & ZONING DIRECTOR

DEVELOPMENT ORDER

File Number: PZ-01-15-2015164
Property Address: 41 NW 105th Street, Miami Shores, FL 33150

Property Owner/Applicant: Corrie Rice
Address: 41 NW 105th Street, Miami Shores, FL 33150

Agent: Mario Averhoff
Address: 11600 NE 13th Avenue, Miami, FL 33161

Whereas, the applicant Corrie Rice (Owner), has filed an application for site plan review before the Planning Board on the above property. The applicant sought approval as follows: Pursuant to Articles IV, V and VI of Appendix A Zoning, Sec. 400 Schedule of Regulations and Sec. 600. Site plan review and approval required. First story addition.

Whereas, a public hearing was held on **February 26, 2015** and the Board, after having considered the application and after hearing testimony and reviewing the evidence entered, finds:

1. The application was made in a manner consistent with the requirements of the Land Development Code of Miami Shores Village.
2. The conditions on the property and the representations made at the hearing merit consideration and are consistent with the requirements of the Land Development Code.

The Board requires that all further development of the property shall be performed in a manner consistent with the site plan, drawings, and the conditions agreed upon at the hearing:

- 1) Approval is granted as shown on the plans submitted and made a part of this approval to construct a 329 sq. ft. one-story playroom / media room addition.
- 2) The site shall not drain onto neighboring or village properties. The plot shall provide storm drainage that detains the first one inch in natural or filtered structural facilities. The applicant is responsible for any site modifications that


become necessary to maintain storm drainage on-site that detains the first one inch in natural or filtered structural facilities. The Building Official may require an architect or engineer's drainage plan and report to certify to the building official that the site will provide storm drainage that will detain the first one inch in natural or filtered structural facilities prior to the drainage work commencing on site. The installation of structures on site to control drainage shall require planning board review and approval. Modifications to the approved drainage plan shall require a signed architect or engineer's drainage plan that shall be subject to review and approval of the Building Official and the Planning Director. Major changes to the approved drainage plan shall require a new site plan review application and review and approval by the Planning and Zoning Board.

- 3) The A/C unit shall not be located within the required 10 ft. side yard setback.
- 4) Applicant to obtain all required building permits before beginning work.
- 5) Applicant to obtain all required permits and approvals from the Miami-Dade Department of Regulatory and Economic Resources, Environmental Plan Review Division (DRER, EPRD) and the Miami-Dade Department of Health (DOH/HRS) as required.
- 6) Applicant to meet all applicable code provisions at the time of permitting.
- 7) This zoning permit will lapse and become invalid unless the work for which it was approved is started within one (1) year of the signing of the development order by the board chair, or if the work authorized by it is suspended or abandoned for a period of at least one (1) year.

The application with conditions was passed and adopted this 26th day of February, 2015 by the Planning and Zoning Board as follows:

Mr. Abramitis	Yes
Mr. Busta	Yes
Mr. Reese	Yes
Mr. Zelkowitz	Yes
Chairman Fernandez	Yes

3/10/2015
Date


Richard M. Fernandez
Chairman, Planning Board