



Miami Shores Village

10050 N.E. SECOND AVE.
MIAMI SHORES, FLORIDA 33138-2382
Telephone: (305) 795-2207
Fax: (305) 756-8972

DAVID A. DACQUISTO, AICP
PLANNING & ZONING DIRECTOR

DEVELOPMENT ORDER

File Number: PZ-03-16-201636
Property Address: 330 NE 97th Street

Property Owner/Applicant: Victoria & James Novack
Address: 330 NE 97th Street, Miami Shores, FL

Agent: Victor Bruce
Address: 370 NE 101 Street, Miami Shores, FL

Whereas, the applicant Victoria & James Novack (Owner), has filed an application for site plan review before the Planning Board on the above property. The applicant sought approval as follows: Pursuant to Articles IV, V and VI of Appendix A Zoning, Sec. 400 Schedule of Regulations and Sec. 600. Site plan review and approval required. Second story addition.

Whereas, a public hearing was held on **April 28**, 2016 and the Board, after having considered the application and after hearing testimony and reviewing the evidence entered, finds:

1. The application was made in a manner consistent with the requirements of the Land Development Code of Miami Shores Village.
2. The conditions on the property and the representations made at the hearing merit consideration and are consistent with the requirements of the Land Development Code.

The Board requires that all further development of the property shall be performed in a manner consistent with the site plan, drawings, and the conditions agreed upon at the hearing:

- 1) Approval is granted as shown on the plans submitted and made a part of this approval to construct a 646 sf second-story addition master bedroom suite.
- 2) Applicant to apply for and obtain all required building permits from the Building Department before beginning work.
- 3) Applicant to apply for and obtain all necessary permits and approvals from outside agencies before beginning work.
- 4) The site shall not drain onto neighboring properties or any rights-of-way. The plot shall provide storm drainage that detains the first one inch in natural or filtered structural facilities. The applicant is responsible for any site modifications that become necessary to maintain storm drainage on-site that detains the first one inch in natural or filtered structural facilities. The Building Official may require an architect or engineer's drainage plan and report to certify to the building official that the site will provide storm drainage that will detain the first one inch in natural or filtered structural facilities prior to the drainage work commencing on site. The installation of structures on site to control drainage shall require Planning and Zoning Board review and approval. Modifications to the drainage plan approved by the building official shall require a signed architect or engineer's drainage plan that shall be subject to review and approval of the Building Official and the Planning Director. Changes to drainage


structures approved by the Planning and Zoning Board shall require a new site plan review application and review and approval by the Planning and Zoning Board. Applicant to obtain all required building permits before beginning work.

- 5) All drainage improvements shall be installed in accordance with the approved drainage plan before final inspection by the Building Official.
- 6) The applicant shall repair and maintain the onsite drainage system in accordance with the approved drainage plan.
- 7) An erosion and sedimentation plan subject to review and approval by the building official is required if ground cover is removed or as required by the building official. Properly installed soil erosion measures (silt fences, straw barriers, etc.) and anti-tracking area at all construction entrances are required to be put in place and maintained if ground cover is removed or as required by the building official. Required erosion control measures must be in place prior to footings inspection.
- 8) Applicant to obtain all required permits and approvals from the Miami-Dade Department of Regulatory and Economic Resources, Environmental Plan Review Division (DRER, EPRD) and the Miami-Dade Department of Health (DOH/HRS) as required.
- 9) Ground cover shall comply with the provisions Division 17 of Appendix A, Village of Miami Shores Code of Ordinances, artificial turf and rock of any kind is specifically prohibited.
- 10) Applicant to meet all applicable code provisions at the time of permitting.
- 11) This zoning permit will lapse and become invalid unless the work for which it was approved is started within one (1) year of the signing of the development order by the board chair, or if the work authorized by it is suspended or abandoned for a period of at least one (1) year.
- 12) Applicant to remove parking from the swale and replace it with grass.

The application with conditions was passed and adopted this 28th day of April, 2016 by the Planning and Zoning Board as follows: Adding condition #12.

Mr. Abramitis	Yes
Mr. Busta	Yes
Mr. Reese	Yes
Mr. Diaz	Yes
Chairman Fernandez	Absent

5/11/16
Date


Robert Abramitis
Vice Chairman, Planning Board