



Miami Shores Village

10050 N.E. SECOND AVE.
MIAMI SHORES, FLORIDA 33138-2382
Telephone: (305) 795-2207
Fax: (305) 756-8972

DAVID A. DACQUISTO, AICP
PLANNING & ZONING DIRECTOR

DEVELOPMENT ORDER

File Number: PZ-12-16-201690
Property Address: 129 NW 96th Street

Property Owner/Applicant: Erik Saccomani
Address: 129 NW 96 Street, Miami Shores, FL

Agent: Keith Gamble
Address: 683 NE 193 Street, Miami, FL 33179

Whereas, the applicant Erik Saccomani (Owner), has filed an application for site plan review before the Planning Board on the above property. The applicant sought approval as follows: Pursuant to Articles IV, V and VI of Appendix A Zoning, Sec. 400 Schedule of Regulations and Sec. 600. Site plan review and approval required. Garage conversion.

Whereas, a public hearing was held on January 26, 2016 and the Board, after having considered the application and after hearing testimony and reviewing the evidence entered, finds:

1. The application was made in a manner consistent with the requirements of the Land Development Code of Miami Shores Village.
 2. The conditions on the property and the representations made at the hearing merit consideration and are consistent with the requirements of the Land Development Code.
-
- 1) The Board requires that all further development of the property shall be performed in a manner consistent with the site plan, drawings, and the conditions agreed upon at the hearing: Approval is granted as shown on the plans submitted and made a part of this approval to convert an existing 441 sf attached garage to a master bedroom suite.
 - 2) The applicant to maintain 2 legal parking spaces on the plot.
 - 3) The finished floor of the garage conversion to be not less than 8 inches above the height at the crown of the road.
 - 4) The front driveway flares not to exceed 5 ft. in width for a total width at the street of not more than 30 feet.
 - 5) Applicant to apply for and obtain all required building permits from the Building Department before beginning work.

- 6) Applicant to apply for and obtain all necessary permits and approvals from outside agencies before beginning work.
- 7) An erosion and sedimentation plan subject to review and approval by the building official is required and must be submitted to the building official with the building permit application. Properly installed soil erosion measures (silt fences, straw barriers, etc.) and anti-tracking area at all construction entrances are required to be put in place and maintained if ground cover is removed or as required by the building official. Required erosion control measures must be in place prior to footings inspection.
- 8) Applicant to obtain all required permits and approvals from the Miami-Dade Department of Regulatory and Economic Resources, Environmental Plan Review Division (DRER, EPRD) and the Miami-Dade Department of Health (DOH/HRS) as required.
- 9) Applicant to meet all applicable code provisions at the time of permitting.
- 10) Applicant to complete a covenant in the form of a "Declaration of Use" assuring the property is used only for a single family purpose, record the covenant with the Miami-Dade County Recorder and provide the planning director with a copy of the recorded document prior to the final inspection by the Building Official.
- 11) This zoning permit will lapse and become invalid unless the work for which it was approved is started within one (1) year of the signing of the development order by the board chair, or if the work authorized by it is suspended or abandoned for a period of at least one (1) year.


The application with conditions was passed and adopted this **26th** day of **January**, 2017 by the Planning and Zoning Board as follows:

Motion to approve subject to Staff's recommendations made by Mr. Snow, seconded by Ms. Hegedus and the vote was unanimous in favor of the Motion.

Mr. Snow	Yes
Mr. Busta	Yes
Ms. Hegedus	Yes
Mr. Diaz	Yes
Chairman Fernandez	Yes

Date

2/8/2017


 Richard M. Fernandez
 Chairman, Planning Board